

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1130:201 Page 1 of 1

CATEGORY: Annunciators

LISTEE: *Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models XLS-3ANN/D and XLS-6ANN/D annunciators. Refer to listee's data sheet for detailed product description and operational considerations. The units are modular in construction. System components:

XLS-3ANN/D, XLS-6ANN/D	Enclosure Door w/Inner Door
6ANNB(-S), 10ANNB(-S)	Back Box
2-LCD	LCD Display Module
2-CPU	Annunciator Motherboard
2-DLM	Data Line Monitor
2-16Y	16 yellow LED Annunciator
2-16R	16 red LED Annunciator
2-16G	16 green LED Annunciator
2-8RY	8 Red/Yellow Annunciator
2-12R4Y	12 Red/4Yellow LED Annunciator
2-8RYS	8 Red/Yellow LED/8 Switch Annunciator
2-16R8S	16 Red LED/8 Switch
2-16Y8S	16 Yellow LED/8 Switch

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciator for use with separately listed compatible fire alarm control units.

XLF: 7120-1388:223

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 14, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager